

C-24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No. F6/DFS/MS/2022/School/WZ/336

Dated: 29/03/2022

**FIRE SAFETY CERTIFICATE**

Certified that the **Ran Singh Model Public School, E-Block, Pratap Vihar-III, (Opp, Sector-21) Kirari, Rohini, Delhi-110085**, comprised of **Two Blocks, Gr.+01 & Gr.+02 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2018/WZ/2382 dated 23.10.2018**. The premises was re-inspected by the officer concerned of this department on **07.03.2022** in the presence of **Mr. Sunil Kumar (Manager)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational "Group B"** with effect from 29/03/2022 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/03/2022 at New Delhi by

  
**(Dhrampal Bhardwaj)**  
**Dy.Chief Fire Officer**  
**Tel;-01123414250**

Copy to :-

1. The Director of Education, Old Secretariat, Delhi
2. The Principal, Ran Singh Model Public School, E-Block, Pratap Vihar-III, (Opp, Sector-21) Kirari, Rohini, Delhi-110085.

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of Rule 37] along with a copy of this Certificate, **six months** prior to its expiry."